

FPUD Job Number 3215 – WRP REPAIR AND LINING

ADDENDUM A

Friday March 1, 2024

Attention All Bidders:

The following clarifications, changes, and/or deletions to the Contract Documents are hereby made as part of the Contract Documents for the above referenced project as fully and as completely as though the same was included therein. This addendum shall be acknowledged on the face of the envelope submitted with the Bid Proposal.

This Addendum "A" includes answers to bidder's questions, clarifications and/or changes to the Contract Documents for the Fallbrook Public Utility District:

CLARIFICATION:

Change Bid Due Date to Wednesday March 13th 2024, 3pm.

Liner type shall be Resin impregnated FELT, using the specified RESIN noted in Specification 03955-8: section 2.1.G.2 - Epoxy-Vinyl-Ester-Resin, or approved equal.

(It is understood that this resin chemistry will be more flexible for lining the DIP that is above ground.)

Additional Pre-Bid Walk: Any interested party may contact Aaron Cook AcCook@fpud.com, 760-999-2713, and/ or Soleil Develle at soleil@fpud.com, 760-999-2717, in order to schedule.